

CITY OF FORT LAUDERDALE

FIRE RESCUE DEPARTMENT

FIRE PREVENTION BUREAU
www.fortlauderdale.gov

528 N.W. 2nd Street
Fort Lauderdale, FL 33311-9108
OFFICE: (954)828-6370
FAX: (954)828-5338

INSPECTION REPORT

INSPECTOR CONTACT INFORMATION: JULIO ARIAS, 954-829-7987
INSPECTION DATE: 09/18/2019

ADDRESS: 2824 NE 33 CT

ZONE:23

OCCUPANT:OAKLAND ARMS CONDO ASSN INC

ACCOUNT: 23010952

VIOLATION(S)

NFPA 101:31.3.4.3.5.1 REPLACE FADED FIRE ALARM SIGNS BY APTS# 1 & 7
TO WIT: Approved signs are not provided at each manual fire alarm
box stating Local Alarm Only - In Ccase of Fire Call 911.

TO CORRECT: Provide approved signs at each manual fire alarm box stating
Local Alarm Only - In Ccase of Fire Call 911.

INSPECTION TYPE: ANN

INSPECTION RESULT (P=Passed, F=Failed, C=Cancelled, I=Incomplete): F

NOTE: A RE-INSPECTION WILL BE MADE:

1 FIRE VIOLATION 4 WEEKS

PROMPT ACTION SHALL BE TAKEN TO CORRECT ABOVE INDICATED VIOLATIONS.
IF CORRECTIONS ARE NOT MADE UPON RE-INSPECTION, AN ADDITIONAL
RE-INSPECTION FEE WILL BE CHARGED FOR EACH SUBSEQUENT INSPECTION.
PERMITS MAY BE REQUIRED TO CORRECT VIOLATIONS.
CHARGED FOR EACH SUBSEQUENT INSPECTION.

SIGNATURE: BY MAIL